

OFFICE OF THE ASSISTANT DIRECTOR FIRE AND EMERGENCY SERVICES
COMMAND RAJOURI / POONCH.

The Principal,
KENDRIYA VIDYALAYA
RAJOURI.

No: - ADRP/FP/ 64-17

Dated:- 11-01-2021

Sub: - Provisional Fire Safety Certificate in favour of Kendriya Vidyalaya Rajouri.

Ref: - Your application No. F.19/KVR/2019-20/475 (a) Dated: 01-06-2020.

Sir,

In reference to above referred letter, the spot inspection of above noted school was carried out. The details are as under.

Details of Building:

The school is double storied concrete building, Ground floor having 07 Nos. Class rooms, 01 No. Principal office, 01 No. staff room, 01 No. clerk room, 01 No. Medical room, 01 No. chemistry lab, 01 No. Computer lab, 02 No. Exam rooms, Toilets/bathroom

First floor having, 05 Nos. Class rooms, 01 No. CMP room, 01 No. Physic lab, 01 No. Physical store 01 No. music room, 01 No. bio lab, 01 No. Library, 01 No. art room, Toilets/bathroom

Location/Accessibility:

The school is located at near Panj Pir Rajouri. It is about 03 km away from the F&ES Station Rajouri and approachable for fire appliances in case of any exigency.

Water Sources:

One underground water storage tank of about 20,000 ltrs. Capacity of water for daily routine is provided.

Exit/Entrance:

The school is double storied and the exit is directly towards the exterior open double entrance/exit gate is provided for the school premises.

Electricity:

The electric fitting are of concealed conduit type with MCB's Provided

First aid fire fighting arrangement:

04 Nos. portable fire Extinguisher of DCP (ABC) type of 05 kg capacity is provided in the school.

Fire detection /suppression:

No fire detection/suppression arrangement whether automatic or manual is provided in the premises at present.


Recommendations:

1. First aid the fire extinguishers need to be augmented,
2. One fire point of four sand filled buckets and two fire beaters should be provided,

3. Telephone No.'s of nearest F&ES stations should be displaced in bold letters at the school.
4. Staff should be properly trained for handling/operating the fire safety system.
5. Fire evacuation drill should be conducted regularly on biannual basis.
6. No combustible and flammable material to be stored in the school rooms.
7. No. addition/alteration shall be made without prior permission of this department.

Subject to the fulfillment of above fire safety recommendations, the school can continue with the operations vis-a-vis the current fire safety arrangements for a period of one year from the date of issue of this letter. *

Yours faithfully,



Assistant Director
Fire & Emergency Services Command
Rajour / Poonch

